



ADDENDUM TO BID PACKAGE #10

LAX – BRADLEY WEST GATES

ADDENDUM NUMBER 02

MARCH 8, 2010

Addendum Issue Date: March 8, 2010

Purpose: The purpose of this Addendum is to make changes, additions, deletions, and revisions to the bidding documents dated November 20, 2009 for the above referenced project. Bidders shall review the Addendum work and requirements in detail and incorporate any effects the Addendum may have in their bid price.

Acknowledgement: Bidders must acknowledge receipt of any and all Addenda in the space provided on the Bid Form. Failure to do so may result in rejection of the Bid.

Note: All requirements of the bidding documents remain unchanged except as cited herein.

Part 1 - Amendments to Bid Documents

- Modification to Instructions to Bidders, Section 7.2:
 - Deadline for bidders questions has been changed to Wednesday, March 17, 2010 at 5:00PM.

Part 2 - Questions from Potential Bidders

Question: Will the contract BIM model be available at no cost to the contractor for the preparation of shop drawings and the coordination process?

Answer: Yes, BIM model will be supplied.

Question: There is a bold dashed line with "Limit of Work" noted above it, are we to stop at this line and not include any work beyond...such as duct or pipe? If so what about Fan Coils N18, N19, N20, 1½" HHWS/R and the 2" CHWS/R going up? Where does the 4" GCHWS/R, 3" HHWS/R and 4" CHWS/R continue to?

Answer: Refer to Design Package #5, Bulletin #2. This has been changed to "Match Line."

End of Addendum 02

WALSH AUSTIN JOINT VENTURE CONTACT INFORMATION

400 Continental Blvd, 6th Floor - Suite 69 | El Segundo, CA 90245

Phone: (310) 426-2892 | Fax: (310) 426-2888

James Augustyn – Procurement Manager